



RECTANGULAR 6" W.G. +/- PRESSURE CLASSIFICATION

LONGEST DIMENSION	MINIMUM GAUGE	JOINT CONNECTION	JOINT REINFORCEMENT	JOINT REINFORCEMENT SPACING	INTERMEDIATE REINFORCEMENT	INTERMEDIATE REINFORCEMENT SPACING	LONGITUDINAL SEAM
0"-8"	26	TDF	-	5'	-	-	PITTSBURGH
9"-12"	24	TDF	-	5'	-	-	PITTSBURGH
13"-20"	22	TDF	-	5'	-	-	PITTSBURGH
21"-26"	24	TDF	-	5'	I-1	30"	PITTSBURGH
27"-30"	22	TDF	-	5'	I-1	30"	PITTSBURGH
31"-36"	20	TDF	-	5'	I-2	30"	PITTSBURGH
37"-42"	20	TDF	J-1	5'	I-2	30"	PITTSBURGH
43"-60"	20	TDF	J-2	5'	I-2	30"	PITTSBURGH
61"-84"	18	TDF	J-3	5'	I-3	30"	PITTSBURGH
85"-120"	16	35DM	-	5'	I-4	30"	PITTSBURGH

J-1: 1 1/2"x1 1/2" X 20 GA HAT CHANNEL

J-2: 2"x1" X 20 GA HAT CHANNEL

J-3: 3"x1 1/2" X 16 GA HAT CHANNEL

I-1: 1 1/2"x3/4" X 18 GA Z-CHANNEL

I-2: 3"x1 1/8" X 16 GA Z-CHANNEL

I-3: 3"x1 1/8" X 10 GA Z-CHANNEL

I-4: 3"x1 1/8" X 10 GA Z-CHANNEL W/TIE ROD 48" O.C.

NOTE:

SEALING REQUIREMENTS COMPLY WITH SMACNA CLASS A, 4" W.G. AND UP
ALL TRANSVERSE JOINTS, LONGITUDINAL SEAMS AND DUCT WALL PENETRATIONS

SUBJECT TO CHANGE W/O NOTICE



9135 KING STREET • ANCHORAGE, ALASKA 99515-1927
PHONE: 907-522-5959 • FAX: 907-522-6006

PROJECT:

ENGINEER:

CONTRACTOR:

TITLE:

GMI-GALV-6